

March 18, 2021

ADDENDUM NO. 2



RE: Rest Room Renovations to
Southern West Virginia Community and Technical College
Williamson, WV Main Building
Architect's Job No. 18047

TO: Prospective Bidders

FROM: ZMM, Inc. Architects and Engineers

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents.

**ATTACH THIS ADDENDUM TO THE FRONT COVER OF THE PROJECT MANUAL AND
ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID
FORM.**

PART 1 - CLARIFICATIONS:

- A. Drawing Sheet A131 – Enlarged Plans and Partition Details: Refer to wall type M2F and delete reference to steel angles at the top of the wall. These partitions will not be required to be braced to the structure.
- B. Note that the base bid work extends to the 3rd, 4th and fifth floors. Any work that is part of the alternate bid, is noted as work on an alternate plan with the word “ALTERNATE” in the view title or has a dashed border around the work with the label “ALTERNATE.”
- C. “Metallic Surface Raceway” is defined in specification 260533 Part 2.5 SURFACE RACEWAYS and the application of such raceway is defined in 260533 Part 3.1.

END OF ADDENDUM

Blacksburg
200 Country Club Drive SW
Plaza One, Building E
Blacksburg, Virginia 24060
540•552•2151

Charleston
222 Lee Street West
Charleston, West Virginia 25302
304•342•0159
www.zmm.com

Martinsburg
5550 Winchester Avenue
Berkeley Business Park, Suite 5
Martinsburg, West Virginia 25405
304•342•0159