
Tower Project Name: WVNCC HVAC Controls and Repairs
Tower Project Number: 2020103
Client: WV Community & Technical College System
Prepared By: Tom Valerio
Date: 09/02/2021

Addendum Number: 5

SPECIFICATIONS

Item No. 5.01

SECTION 012300 Alternates, Article 3.1 Schedule of Alternates

DELETE Paragraph P. Alternate No. 7.3: Repair Weirton Campus RTU-11 in its entirety and replace with the following:

- P. Alternate No. 7.3: Repair Weirton Campus RTU-11.
1. Base Bid: Do not repair RTU-11 mechanical components serving the Weirton Campus. Provide DDC control components to accomplish the sequence described in Section 230993.07 "Weirton Campus - Sequence of Operations for HVAC Control", Article 3.1 Constant Air Volume Packaged Rooftop Units - Weirton RTUs 1 through 14.
 2. Alternate: Replace the BACnet communication card serving RTU-11. Provide DDC control components to accomplish the sequence described in Section 230993.07 "Weirton Campus - Sequence of Operations for HVAC Control", Article 3.1 Constant Air Volume Packaged Rooftop Units - Weirton RTUs 1 through 14.

END OF ADDENDUM