

**SECTION 00 91 12
ADDENDUM NUMBER 1**

PARTICULARS

1.01 DATE: February 14, 2022

1.02 PROJECT: Pierpont Vet Tech

1.03 OWNER: WV Higher Education

1.04 ARCHITECT: PICKERING ASSOCIATES

TO: PROSPECTIVE BIDDERS:

2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL PROCUREMENT DOCUMENTS DATED FEBRUARY 1, 2022, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.

2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

3.01 MANDATORY PRE-BID MEETING:

See attached sign-in sheet and meeting minutes – 4 pages.

SPECIFICATIONS:

1. Use attached Final Report from Astar – 7 pages.
2. Specification Section 10 51 13 – Metal Lockers: Paragraph 2.01.A. Add Scranton Products: www.scrantonproducts.com, as an approved manufacturer.

CONTRACTOR QUESTIONS:

Q1: Is Edwards, EST fire alarm acceptable?

A1: Yes.

Q2: Is the generator and transfer switch to be in Alternate 3 or Base Bid?

A2: The generator and transfer switch shall be installed in Base Bid.

Q3: Please clarify what fixture they are referring to on sheet E110 note 1. We do not see a fixture J on the schedule.

A3: Fixture 'J' is Williams #8DR-L60/835-120-DIM-120-OW-WH-WET/CC-N-BA1 or equal.

END OF SECTION