

**RFQ BV2526-004 – HVAC Maintenance and Repair Services**  
**Addendum #1 – Questions and Answers**

**Q1.** Page 5 section 1.15 shows a mandatory pre bid was held on 3-30-26. Can you verify only Casto and Alpha will be able to submit a bid? From my understanding, there were no other companies nor representatives on the walk through nor present when we were dismissed in the lobby.

**A1.** Only bids submitted by vendors that attended the mandatory pre-bid meeting will be accepted.

**Q2.** The equipment listed on pg. 10 section 4.3 just shows (2) boilers and (158) WSHP units. There is no mention of the cooling tower, pumps, or DOAS unit. Would you like those included?

**A2.** Yes. The scope shall include all associated HVAC system components, including but not limited to the cooling tower, pumps, and DOAS unit.

**Q3.** Page 2 shows the schedule of events stating the bids are due at 12pm on 4-21-26, but they will be publicly opened and read at 1pm. Will Alpha and Casto be able to attend the opening?

**A3.** Yes, bidders may attend the bid opening. However, no award decision will be made at that time. Proposals will be evaluated by a committee, and pricing will not be opened until the technical evaluation has been completed.